

# GAS INNOVATIONS

## CERTIFICATE OF CONFORMANCE

### UL Classified, R600a, ISOBUTANE

### REFRIGERANT GRADE

#### Guaranteed Specifications

#### Minimal Purity

99.5 % +

Isobutane

99.50 % +

Sum of all impurities to

Methane

< 1 PPM

be < 0.50 %

Ethane

< 1 PPM

Water < 5 PPM

Propane

< 70 PPM

n-Butane

< 3000 PPM

Isopentane

< 2 PPM

N-pentane

< 3 PPM

#### Liquid Phase Analysis

Water

< 3 PPM

CO + CO<sub>2</sub>

< 5 PPM

Sulfur

Non Detected

Nitrogen

< 10 PPM

Oxygen

< 5 PPM

Certified by: \_\_\_\_\_

Date: \_\_\_\_\_

SO# 000

Cylinder Serial Number(s)

Batch Number

IBU-011718- R600a-UL

**CUSTOMER PO#: 000**

Lot Number: IBU-011718-R600a-UL

18005 E. Highway 225, La Porte, TX 77571 Tel- 281-471-2200 Fax- 281-471-2201 [www.gasinnovations.com](http://www.gasinnovations.com)