

GAS INNOVATIONS

CERTIFICATE OF CONFORMANCE N-BUTANE R-600 REFRIGERANT GRADE

Guaranteed Specifications

99.5 % +

Sum of all impurities to

be < 0.50 %

Water < 5 PPM

Liquid Phase Analysis

Minimal Purity

99.50 % +

18 PPM

< 1500 PPM

< 20 PPM

< 20 PPM

< 550 PPM

< 5 PPM

< 2 PPM

< 10 PPM

Non Detected

n-Butane

Ethane

Isobutane

Propane

Isopentane

Neo-pentane

Water

Oxygen

Nitrogen

Sulfur

Certified by: _____

Date: _____

SO# 000

Cylinder Serial Number(s)

Batch Number

BUT-111018-R600

CUSTOMER PO#: 000

Lot Number: BUT-111018-R600