

GAS INNOVATIONS

CERTIFICATE OF ANALYSIS UL Classified, R600a, ISOBUTANE REFRIGERANT GRADE

<u>Guaranteed Specifications</u>		<u>Lot Analysis</u>
99.5 % +	Isobutane	99.76 % +
Sum of all impurities to be < 0.50 %	Methane	< 1 PPM
	Ethane	< 1 PPM
Water < 5 PPM	Propane	135 PPM
	Propylene (Propene)	< 1 PPM
	n-Butane	2218 PPM
	Pentene's	Not Detected
	Butene-1	Not Detected
	Isobutylene	Not Detected
	Isopentane	< 1 PPM
	N-pentane	< 1 PPM
Liquid Phase Analysis	Water	< 3 PPM
	Carbon Dioxide	< 0.01 PPM
	Sulfur	Not Detected
	Nitrogen	< 10 PPM
	Oxygen	< 5 PPM

Certified by: _____

Date: _____

Cylinder Serial Number(s)

SO# 000

Batch Number

IBU-072419- R600a-UL

CUSTOMER PO#: 000

Lot Number: IBU-072419-R600a-UL

18005 E. Highway 225, La Porte, TX 77571 Tel- 281-471-2200 Fax- 281-471-2201 www.gasinnovations.com